

STATE OF MAINE DEPARTMENT OF HUMAN SERVICES DIVISION OF HEALTH ENGINEERING 11 STATE HOUSE STATION AUGUSTA, MAINE 04333-0011

Bulk Water Hauling

JOHN R. NICHOLAS ACTING COMMISSIONER

At some point, pump failure, water quality or quantity problems may make it necessary for you to haul bulk water to supplement your water supply. Hauling water to your site should only be considered a temporary solution to a water shortage problem. You should only consider hauling water from an approved public water supply. The following provides information on the proper procedures for completing this task.

First, you <u>must</u> contact Scott Whitney at the Drinking Water Program (DWP) before any bulk transported water is distributed to your consumers. According to 22 MRSA § 2660, no person shall transport water for commercial purposes by pipeline or other conduit or by tank truck or in a container greater than ten gallons, beyond the boundaries of the municipality or township in which water is naturally located or any bordering municipality or township without first receiving prior written approval by the DWP.

In case of an emergency, any person may transport water as necessary for the duration of the emergency, but the person transporting the water <u>must</u> inform the DWP within three days (preferably before transporting water) and the DWP may determine when the emergency is over. Any person who transports water and does not notify the DWP within three days is guilty of illegal transport of water. Illegal transportation of water is a Class D crime. Each shipment is a separate offense.

Information Required by DWP:

- 1. When will the bulk water transport occur?
- 2. How much water will be transported?
- 3. What is the water treatment process at the water supplier, during transport and at the recipient?
- 4. What is the recipient's name, PWSID #, address, and telephone number?
- 5. What is the trucker's name, address and phone number?
- 6. What is the water supplier's name, PWSID #, address and telephone number?

Water shall be bulk transported and stored in NSF (food grade) approved potable water tanks (e.g. stainless steel, or polyethylene). Tankers that have been previously used to haul non-food commodities such as toxic materials, petroleum products or other harmful substances shall <u>not</u> be used to haul drinking water for human consumption. Tankers shall be cleaned, sanitized and inspected internally for tank integrity on a routine basis.

Cleaning and disinfection of tank container:

- 1. Inspect the container to ensure that it is water tight and free of debris.
- Disinfect the container for 30 minutes at 200 mg/l (AWWA Standards). 0.4 gallons of household bleach makes a 200 mg/l chlorine residual in 100 gallons of water. Allow disinfection water to flow through all pipes and overflows.
- 3. Mix the solution throughout the container.
- 4. Drain and rinse the container (dispose of chlorinated water in accordance with Local and State regulations). Fill container with water from a public supply. Ensure that the free chlorine residual in the container is at least 0.5 mg/l. Record this measurement on the shipping form.
- 5. Lock a secure padlock on the access hatch to the container to prevent unauthorized access and potential contamination.
- 6. Collect a chlorine residual from each container every 24 hours. The results of these tests are to be written down on the form provided by the DWP and kept with each container shipment.

Drilling a replacement well is probably the best long-term solution to water shortage problems. For more information regarding new well approval, please contact Haig Brochu at (207) 287-6542.